

7 ° Piso	7TA	9				1		1	1 TETRA	1 tetra polar	1 TETRA
	7TA1	1	3							40/30	
	7TB	12				1			1 TETRA		1 TETRA
	7TB1		9								
	7TC	15	2			1			1 TETRA		1 TETRA
	7TC1		9								
8 ° Piso	8TA	3	1			1		1	1 TETRA	1 tetra polar	
	8TB	13	4			1			1 TETRA	40/30	1 TETRA
	8TB1		7	1		1					
	8TC	12	5			1			1 TETRA		1 TETRA
	8TC1		7			1					
9 ° Piso	9TA	2				1		1	1 TETRA	1 tetra polar	
	9TA1		2							40/30	
	9TB	15	1	1					1 TETRA		1 TETRA
	9TB1		7			1					
	9TC	20				1			1 TETRA		1 TETRA
	9TC1		7								

TABLERO GENERAL SUBSUELO

Subsuelo								17	1 de 160A
Opcion 1									
tablero	SUSTITUIR POR 17 INTERRUPTORES 100 A TETRAPOLAR EN CAJA MOLDEADA								
existente	INSTALAR 1 INTERRUPTORES EN CAJA MOLDEADA DE 160A TETRAPOLAR PARA GRAL DE ASCENSORES								

Opcion 2	
tablero	INSTALAR 17 INTERRUPTORES EN CAJA MOLDEADA DE 100A TETRAPOLAR
nuevo	INSTALAR 1 INTERRUPTORES EN CAJA MOLDEADA DE 160A TETRAPOLAR PARA GRAL DE ASCENSORES

