

## JUZGADOS DE Bme. Mitre 1275

Derivaciones de tableros actuales					Proyectado a replantar en obra						
tablero	ubicación	total circuitos II	total circuitos III	gral	Tipo 1	Tipo 2	10A II	16A II	dif 25A IV	100A III	40A III
1	SS	13	1	40A		1	6	9	3		2
2	SS	18			1		9	12	6	1	1
3	PB	14	1	100A	1		8	12	6	1	1
4	PB	11		100A	1		6	8	4	1	1
5	PB	6		40A		1	4	8	3		1
6	PB	10		?		1	6	8	3		1
7	EP	19		?		1	8	12	6		1
8	EP	15	2	40A	1		7	10	4	1	1
9	EP	10		?		1	6	6	4		1
10	P1	22		?	1		10	12	6		1
11	P1	6		?		1	5	5	3		1
12	P1	24	2	??	1		12	14	6	1	2
13	P2	19	1	40A	1		8	17	6	1	1
14	P2	22		??	1		10	12	6		1
15	P3	10	1	MB 75A??	1		6	6	4	1	1
16	P3	9		25A		1	6	8	3		1
17	P3	10	1	50A		1	6	9	3		1
18	P3	8	2	50A ??		1	6	9	3		2
19	P4	19		??	1		10	12	6		1
20	P4	6		50A		1	6	6	3		1
21	P4	25		100A	1		8	17	6	1	1
22	P5	ascensores				ver detalle					
23	P5	19		50A ??	1		8	17	6	1	1
		<b>315</b>	<b>11</b>		<b>12</b>	<b>10</b>	<b>161</b>	<b>229</b>	<b>100</b>	<b>9</b>	<b>25</b>