

Juzgado Penal Fray Bentos

Planilla de cargas

3x230V

Tablero PA									cálculos			
circ.	destino	carga (W)	cond. (mm2)	circ.	caño	interr.	diferencial	obs.	C.U.	W ef.	cos ø	Var
1	luces 4L1+1L2+extr.	295	2x1+2T	II	20 PVC	10A II			1	295	0.95	97.0
2	luces 7L2+2L3	135	2x1+2T	II	20 PVC	10A II			1	135	0.95	44.4
3	luces 4L1+2L2+1L5+2 extr.	419	2x1+2T	II	20 PVC	10A II			1	419	0.95	137.7
4	luces 8L1	360	2x1+2T	II	20 PVC	10A II	25A II 30mA	agrupa 4 circuitos	1	360	0.95	118.3
5	luces 1L8	20	2x1+2T	II	20 PVC	10A II			1	20	0.95	6.6
6	luces 4L8	80	2x1+2T	II	20 PVC	10A II			1	80	0.95	26.3
7	luces 3L4E	45	2x1+2T	II	20 PVC	10A II			1	45	0.95	14.8
8	reserva	100		II		10A II			1	100	0.95	32.9
9	reserva	100		II		10A II	25A II 30mA	agrupa 5 circuitos	1	100	0.95	32.9
												0.0
101	AA 12000BTU	1200	2x2+2T	II	25 PVC	16A II			0.9	1080	0.85	669.3
102	2 PT2	600	2x2+2T	II	25 PVC	16A II			0.6	360	0.85	223.1
103	2 tomas	600	2x2+2T	II	25 PVC	16A II			0.5	300	0.85	185.9
104	AA 12000BTU	1200	2x2+2T	II	25 PVC	16A II			0.9	1080	0.85	669.3
105	1 PT2	600	2x2+2T	II	25 PVC	16A II	40A IV 30mA	agrupa 5 circuitos	0.6	360	0.85	223.1
106	4 tomas	1200	2x2+2T	II	25 PVC	16A II			0.5	600	0.85	371.8
107	AA 12000BTU	1200	2x2+2T	II	25 PVC	16A II			0.9	1080	0.85	669.3
108	2 PT2	600	2x2+2T	II	25 PVC	16A II			0.6	360	0.85	223.1
109	1 toma schuko (impresora)	300	2x2+2T	II	25 PVC	16A II			0.6	180	0.85	111.6
110	3 tomas	900	2x2+2T	II	25 PVC	16A II	40A IV 30mA	agrupa 5 circuitos	0.5	450	0.85	278.9

Juzgado Penal Fray Bentos

Planilla de cargas

3x230V

Tablero PA									cálculos			
circ.	destino	carga (W)	cond. (mm2)	circ.	caño	interr.	diferencial	obs.	C.U.	W ef.	cos ø	Var
111	AA 9000BTU	1000	2x2+2T	II	25 PVC	16A II			0.9	900	0.85	557.8
112	3 PT2	900	2x2+2T	II	25 PVC	16A II			0.6	540	0.85	334.7
113	AA 18000BTU	1800	2x4+4T	II	25 PVC	20A II			0.9	1620	0.85	1004.0
114	1 toma exterior	300	2x2+2T	II	25 PVC	16A II			0.5	150	0.85	93.0
115	2 PT2 + toma sch. Impr.	900	2x2+2T	II	25 PVC	16A II	40A IV 30mA	agrupa 5 circuitos	0.6	540	0.85	334.7
116	2 tomas	900	2x2+2T	II	25 PVC	16A II			0.5	450	0.85	278.9
117	2 PT2	600	2x2+2T	II	25 PVC	16A II			0.6	360	0.85	223.1
118	2 tomas	600	2x2+2T	II	25 PVC	16A II			0.5	300	0.85	185.9
119	reserva	600		II		16A II			0.5	300	0.85	185.9
120	reserva	600		II		16A II			0.5	300	0.85	185.9
121	reserva	600		II		16A II	40A IV 30mA	agrupa 6 circuitos	0.5	300	0.85	185.9
	General	18754	3x16+16N+16T	IV	40 PVC	63A IV		desde Tab PB1		13164		7706.0