

Juzgado Penal Fray Bentos

Planilla de cargas

3x230V

| Tablero PB3 | | | | | | | | | cálculos | | | |
|-------------|--------------------|-----------|--------------|-------|--------|-------------|-------------|--------------------|----------|-------|-------|--------|
| circ. | destino | carga (W) | cond. (mm2) | circ. | caño | interruptor | diferencial | obs. | C.U. | W ef. | cos ø | Var |
| 1 | lucos 11L1 | 495 | 2x1+2T | II | 20 PVC | 10A II | | | 1 | 495 | 0.95 | 162.7 |
| 2 | lucos 1L7 | 15 | 2x1+2T | II | 20 PVC | 10A II | | | 1 | 15 | 0.95 | 4.9 |
| 3 | lucos 2L4E | 30 | 2x1+2T | II | 20 PVC | 10A II | | | 1 | 30 | 0.95 | 9.9 |
| 4 | lucos 2L4E | 30 | 2x1+2T | II | 20 PVC | 10A II | | | 1 | 30 | 0.95 | 9.9 |
| 5 | lucos 3L2+4L9+2L12 | 115 | 2x1+2T | II | 20 PVC | 10A II | 25A II 30mA | agrupa 5 circuitos | 1 | 115 | 0.95 | 37.8 |
| 6 | lucos 3L4E | 45 | 2x1+2T | II | 20 PVC | 10A II | | | 1 | 45 | 0.95 | 14.8 |
| 7 | lucos 2L8 | 40 | 2x1+2T | II | 20 PVC | 10A II | | | 1 | 40 | 0.95 | 13.1 |
| 8 | lucos 7L9 | 105 | 2x1+2T | II | 20 PVC | 10A II | | | 1 | 105 | 0.95 | 34.5 |
| 9 | reserva | 100 | | II | | 10A II | | | 1 | 100 | 0.95 | 32.9 |
| 10 | reserva | 100 | | II | | 10A II | 25A II 30mA | agrupa 5 circuitos | 1 | 100 | 0.95 | 32.9 |
| | | | | | | | | | | | | 0.0 |
| 101 | 2 tomas | 600 | 2x2+2T | II | 25 PVC | 16A II | | | 0.5 | 300 | 0.85 | 185.9 |
| 102 | 1 toma | 300 | 2x2+2T | II | 25 PVC | 16A II | | | 0.5 | 150 | 0.85 | 93.0 |
| 103 | 2 tomas | 600 | 2x2+2T | II | 25 PVC | 16A II | | | 0.5 | 300 | 0.85 | 185.9 |
| 104 | portón | 1000 | s/pl(3x2+2T) | IV | 32 PVC | 16A IV | | | 0.4 | 400 | 0.85 | 247.9 |
| 105 | reserva | 600 | | II | | 16A II | | | 0.5 | 300 | 0.85 | 185.9 |
| 106 | reserva | 600 | | II | | 16A II | 40A IV 30mA | agrupa 6 circuitos | 0.5 | 300 | 0.85 | 185.9 |
| | | | | | | | | | | | | |
| | General PB3 | 4775 | 3x4+4N+4T | IV | 32 PVC | 25A IV | | de Tab PB1 | | 2825 | | 1437.9 |