

### **Solicitaciones transmitidas por las torres de 150kV**

#### **Torre S2**

Hip: viento arrachado a 30°

Altura a la mensula	Traccion (kg)	Cortatne (kg)		Compresion (kg)	Cortatne (kg)	
		X	Y		X	Y
20.5	50896	5584	5961	54419	5956	6313
22.5	53250	5680	6414	57067	6102	6845
26.5	56896	6500	7010	61125	6993	7480
30.5	61039	7128	7754	65786	7692	8290
34.5	65327	7378	8444	70601	7988	9052

#### **Torre SE5**

Hip: viento arrachado a 30°

Altura a la mensula	Traccion (kg)	Cortatne (kg)		Compresion (kg)	Cortatne (kg)	
		X	Y		X	Y
32.5	69715	7670	8669	75271	8312	9310

#### **Torre R15**

Hip: viento arrachado a 30°

Altura a la mensula	Traccion (kg)	Cortatne (kg)		Compresion (kg)	Cortatne (kg)	
		X	Y		X	Y
26.5	89483	10052	11198	95358	10783	11892

#### **Torre A30**

Hip: viento arrachado a 30°

Altura a la mensula	Traccion (kg)	Cortatne (kg)		Compresion (kg)	Cortatne (kg)	
		X	Y		X	Y
26.5	106564	13207	14444	113272	14161	15329

#### **Torre T45**

Hip: viento arrachado a 45°

Altura a la mensula	Traccion (kg)	Cortatne (kg)		Compresion (kg)	Cortatne (kg)	
		X	Y		X	Y
26.5	156024	22111	20784	164381	22038	23350