



TABLERO CH						SALA MAGNA IZQUIERDA ESCANERO	
IND. NO	5 mm2	1 mm2	4 mm	BANDEJA	ELEMENTOS TABLERO DIFERENCIA	OBSERVACIONES	
	4x4	1x4	25	X	4x25	A.A. GRANDE LADO IZQUIERDO	
0	3x6	1x6			3x20	4x40/30x6	
1	2x1	1x2	25	X	1x10	LUZ	
2					1x10	LIBRE/RESERVA	
3					1x10	LIBRE/RESERVA	
4	2x2	1x2	25	X	1x10	1 TOMACORRIENTE 3 EN LINEA	
5					2x40	LIBRE/RESERVA	
6	2x2	1x2			2x40	TOMACORRIENTE	

MEDICIONES		HORA: 14:00		FECHA: 20/05/2017	
Urs:	389 V	Vm:	230 V	Vncs:	5 V
Ust:	388 V	Vsn:	217 V	Is:	0.003 A
Utr:	394 V	Vtn:	225 V	Is:	0.105 A
				Ics:	0.023 A



TABLERO		GJ				ESC. AUDITORIO	
DER. No.	S mm2	T mm2	Ø mm	BANDEJA	ELEMENTOS INTERRUP.(A)	TABLEROS DIFERENCIAL	OBSERVACIONES
G	3x6	1x6	32		3x32	4x25A/30mA	
1	2x1		20				LUCES
2	2x2		20				TOMACORRIENTE
3	2x1		20				LUCES
4	2x2		20				TOMACORRIENTE

MEDICIONES		HORA: 16:00		FECHA: 26/05/2017	
Urs:	391.6 V	Vrm:	222.2 V	Vnca:	1.6 V
Ust:	394.8 V	Van:	227 V	Is:	6.90 A
Utr:	392.9 V	Vrn:	219.5 V	Ia:	0.055 A
				Iac:	0.024 A